

PITTSYLVANIA COUNTY
VIRGINIA



Connie Gibson, Procurement
Manager
1 Center Street Virginia
Phone (434) 432-7744
Website:
www.pittsylvaniacountyva.gov

November 25, 2019

RE: IFB# 20191104

The following shall serve as Addendum #1. Please acknowledge receipt of this addendum when submitting your bid.

Dear Vendor:

All contractors, subcontractors, suppliers, and vendors submitting Bids on or related to this project shall incorporate in their Bids all items as described herein, and further, shall acknowledge on the Bid Form, the receipt of this and any future Addenda.

Item One: Geotextile Fabric

Geotextile fabric shall be installed 12.5 feet wide on the entire route of the trail on the subgrade. A woven geotextile by US Fabrics (US 200) or approved equal shall be included in the base bid.

Item Two: Alternate 2

For Alternate 2, 4" of VDOT 21-A or VDOT 21-B Stone Base shall be included to the alternate in addition to the 2" of VDOT Std. SM-9.5A Bituminous Surface Course.

Sincerely,

Connie Gibson

Connie Gibson
Purchasing Manager